



SECOND ADDENDUM TO INVITATION TO BID

ROCK CREEK CLARIFIERS NO. 1-3 CONCRETE LAUNDER REPAIRS

PROJECT NO. 7297

CLEAN WATER SERVICES

ISSUED: JULY 13, 2026

Clean Water Services' Invitation to Bid for Invitation for Rock Creek Clarifiers No. 1-3 Concrete Launder Repairs Project No. 7297 dated June 22, 2026 (ITB) is hereby amended as follows:

Make the following changes to the ITB Documents:

Item # Volume Description

2.1		<u>Questions and Answers:</u> <u>Q1:</u> Can the Owner provide confined space rescue team when or if required? <u>A1:</u> No. The Contractor is required to provide their own Confined Space Rescue Team (CSRT) when and if required. <u>Q2:</u> We have concern about damage to the aluminum roof structure from flying rock at high speed created by the hydro demolition process specified, would hand chipping be an acceptable removal method in lieu of hydro-demolition? <u>A2:</u> Yes, hand chipping would be acceptable. Regardless of the chosen method of removal, the preparation of the concrete must still meet the same roughness amplitude and ICRI requirements listed in the Specifications. As a reminder, the Contractor is responsible to repair or replace all materials, structures or equipment damaged by or as a result of their work.
-----	--	--

Except as modified in this Addendum, the ITB will remain in effect as originally written.